

Generac Power Systems, Inc.
S45 W29290 Hwy. 59
P.O. Box 8
Waukesha, Wisconsin 53187
P (262) 544-4811
F (262) 544-1241



To Whom it may concern,

This letter is to confirm that Portland General Electric has approved Generac Integrated Meter Socket Switches for use in their territory. The list of the approved models are as listed below:-

Overhead(OH) Entry only

- 1) **RXUW200A3** --- 200A Integrated Meter Socket Automatic Transfer Switch.
- 2) **RXUW150A3** --- 150A Integrated Meter Socket Automatic Transfer Switch.
- 3) **RBU200A3** --- 200A Builders Unit Upgradeable to Integrated Meter Socket Automatic Transfer Switch.
- 4) **RBU150A3** --- 150A Builders Unit Upgradeable to Integrated Meter Socket Automatic Transfer Switch.

***Important:** These models come standard as ringless, which are not approved. Only ringed bases are accepted at PGE. Be sure to procure accessory G0074010 as needed and that horn bypass is removed with meter panel cover change out.

Underground(UG) Entry only

- 5) **RXGUW200A3** --- 200A Integrated Meter Socket Automatic Transfer Switch with 42circuit 200A main panel and field wiring section.

****Important:** This model comes standard with horn bypass, which are not approved. Ensure horn bypass is removed.

Please contact Generac if you have any questions or concerns.

Sincerely,
Sie Teong Lim
Product Manager – Residential ATS



Email – Sie.TeongLim@Generac.com
GENERAC POWER SYSTEMS
S45W29290 HIGHWAY 59
WAUKESHA, WI 53189